



CITY OF RIVERSIDE FIRE DEPARTMENT

Incident Information Fact Sheet



Incident Name: Central Incident

Incident Location: 5500 block of Central Ave

Type of Incident: Structure Fire

Incident Number: 15-04367

Date Reported: 02/18/2015

Time Reported: 7:19 AM

Fatalities: 0 **Critical:** 0 **Moderate:** 0 **Minor:** 0 **Non Injury:** 0

Transported Ground Ambulance(s): 0

Loss: \$0

Save: \$0

Cause: Electrical

Control Time:

Evacuations: No

Evacuation Comments:

RESOURCES ASSIGNED

Fire Fighters: 15

Engine Companies: 2

Truck Companies: 2

Specialized Equipment:

Overhead Personnel: 2

Ambulance(s): 0

Water Tenders: 0

Utilities: Yes

Red Cross: No

Displaced Persons: No

CURRENT SITUATION

(Recent updates are posted at the top of Current Situation)

The City of Riverside Fire Department responded a first alarm assignment to a report of a structure fire in the 5500 block of Central Ave. Upon arrival, firefighters found a single story residential structure with light smoke coming from inside the house. Once firefighters made entry into the structure they checked for extension in the wall and found some of the wood smoldering from electrical wiring. As firefighters searched the structure they found possible marijuana grow house. One resident was found inside the home in the attic space. Riverside Public Utilities were called out for possible illegal wiring at the main electrical panel. The Riverside Police Department (RPD) was notified and the scene was turned over to RPD. The dollar loss was approximately \$7,000 and the save on the structure was approximately \$180,000. For any further questions you can contact RPD.

COOPERATING AGENCIES

RPU, Riverside Police

Prepared By:

Date/Time Posted: 02/18/2015 0719

Information Center: 951.826.5321

Follow us on Twitter: rivcafire